

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE N/A	PAGE OF PAGES 1
2. AMENDMENT/MODIFICATION NO. 0006	3. EFFECTIVE DATE AUGUST 27, 200	4. REQUISITION/PURCHASE REQ. NO. N/A	5. PROJECT NO. (If applicable)	
6. ISSUED BY DEPARTMENT OF THE ARMY U.S. ARMY ENGINEER DISTRICT, LOS ANGELES LOS ANGELES, CALIFORNIA 90053-2325		7. ADMINISTERED BY (If other than Item 6) DEPARTMENT OF THE ARMY US ARMY CORPS OF ENGINEERS, LOS ANGELES DISTRICT P.O. BOX 532711 LOS ANGELES, CALIFORNIA 90053-2325		
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)		(√) 9A. AMENDMENT OF SOLICITATION NO. DACA09-03-B-0009		
		X 9B. DATED (SEE ITEM 11) N/A		
		10A. MODIFICATION OF CONTRACTS/ORDER NO.		
		10B. DATED (SEE ITEM 13)		
CODE	FACILITY CODE			

### 11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

N/A NOTE: ITEM 13 BELOW IS N/A

### 13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

(√)	X	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A. N/A
		B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
		C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
		D. OTHER (Specify type of modification and authority)

**E. IMPORTANT:** Contractor ☐ is not, ☐ is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

UAV TRAINING FACILITY, FT HUACHUCA, ARIZONA

Amendment 0006 is issued to include the graph that was ommitted in Amendment 003, under Request for Information Report No. UAV-005.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR  (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA  BY (Signature of Contracting Officer)	16C. DATE SIGNED

---

# REQUEST FOR INFORMATION REPORT

REPORT NO. UAV-005

---

DATE RECEIVED	12/08/03	PROJECT	UAV Training Facilities
RECEIVED BY	NEUMYER	LOCATION	Ft. Huachuca AZ
DATE NEEDED	ASAP	P.O.C.	Sandra Oquita/Garry Hill
ARCHITECT	NEUMYER	PHONE	213-452-3249/916-557-6935
DATE COMPLETED	12/08/03	REQUESTED BY	CESPL
APPROVED BY	_____	SPEC. NO.	1312

---

**PROBLEM TITLE:** Landscape items

**PROBLEM STATEMENTS:** 1. Sheet L1.01 shows layout for the Masonry Site Walls. Most of the dimensions are not modular. This will require extensive cutting of CMU. Are these the correct dimensions?

2. There is no mention of Durowal in Spec. Section 04200. Does this mean none is required?

3. We find no Product ID or Manufacturer for the "Octo Stone" Pavers. Is there a Manufacturer?

4. Sheet L1.01 shows two (2) radius Walls. The radius is too small to use 8 x8x16 CMU. We are figuring to use 8x8x8 halves. Please confirm.

5. Drawing C1.61 makes reference to a Match Line show on C1.62. The match Line shown on C1.62 does not appear to match the line shown on C1.61. This will affect the length of the utility lines. Please clarify.

## RESPONSES:

1. The dimensions on sheet L1.01 indicate the locations/dimensions for the ground paving and pavers not the cmu walls. The cmu walls should be placed adjacent to the paved areas. The actual cmu wall does not have to be the exact length of the pavement area because it located within corner and turns in the pavement. On the circular entry wall that will serve as a visual screen for the mechanical equipment that is located in front of the new building there may have to be some cutting to make that work.

2. Correct. Durowal is not part of this project.

3. You are correct. I was trying to match the paver blocks on existing UAV building. A block that looks similar to the existing UAV building will be acceptable. I believe

---

CC: CSS, PM, TECH MGR, CESPL-CO

the uni-decostone is a pretty similar and commonly available. See graphic below of the shape.

4. You are correct.

5. Matchline corrected on Amendment #1.

